

I - 10

Class I, Div. 1 and 2
Groups A,B,C,D
Class II, Div. 1 and 2
Groups E,F,G
Class III

EYS Grayloy™ - Iron Sealing Fittings: Explosionproof, Dust - Ignitionproof, Raintight UNILETS® for use with Threaded Metal Conduit

			Kwiko® A		Catalog Number Grayloy™-Iron*	
Size (Inches)	Turning Radius† Inches	(cm)	Cement Req'd Ozs.	(Grams)		
EYS Vertical and Horizontal Conduit Seals (25% fill)** for Close Turning Radius						
Female						
 1/2—1" 1-1/4—3" 3-1/2—6"	1/2	1.16	(2.9)	1	(28)	EYS-11+
	3/4	1.25	(3.2)	2	(57)	EYS-21+
	1	1.38	(3.5)	4	(113)	EYS-31+
	1-1/4	1.75	(4.4)	9	(255)	EYS-4
	1-1/2	2.06	(5.2)	12	(340)	EYS-5
	2	2.31	(5.9)	21	(595)	EYS-6
	2-1/2	2.69	(6.8)	37	(1,049)	EYS-7
	3	3.13	(7.9)	61	(1,729)	EYS-8
	3-1/2	3.44	(8.7)	80	(2,268)	EYS-9
	4	3.69	(9.4)	112	(3,175)	EYS-10
	5	4.69	(11.9)	198	(5,613)	EYS-012
	6	5.38	(13.7)	230	(9,667)	EYS-014
Male/Female (Removable Male Nipple)						
	1/2	1.16	(2.9)	1	(28)	EYS-116+
	3/4	1.25	(3.2)	2	(57)	EYS-216+
	1	1.38	(3.5)	4	(113)	EYS-316+
	1-1/4	1.75	(4.4)	9	(255)	EYS-46
	1-1/2	2.06	(5.2)	12	(340)	EYS-56
	2	2.31	(5.9)	21	(595)	EYS-66
	2-1/2	2.69	(6.8)	37	(1,049)	EYS-76
	3	3.13	(7.9)	61	(1,729)	EYS-86
	3-1/2	3.44	(8.7)	80	(2,268)	EYS-96
	4	3.69	(9.4)	112	(3,175)	EYS-106
	5	4.69	(11.9)	198	(5,613)	EYS-0126
	6	5.38	(13.7)	230	(9,667)	EYS-0146
Female/Male EYS						
EYS Grayloy™ - Iron Vertical Sealing Fittings (25% fill)**						
Female						
 Female Male	1/2	1.63	(4.14)	1	(28.4)	EYS-1+
	3/4	1.91	(4.85)	2	(56.8)	EYS-2+
	1	2.38	(6.05)	3	(85.1)	EYS-3+
Male/Female (Removable Male Nipple)						
	1/2	1.63	(4.14)	1	(28.4)	EYS-16+
	3/4	1.91	(4.85)	2	(56.8)	EYS-26+
	1	2.38	(6.05)	3	(85.1)	EYS-36+

* Shaded area indicates items which are U.L. Listed for Class I, Groups A,B,C, and D; Class II, Groups E,F and G; and Class III.

* U.L. Listed for use with Appleton "Kwiko® A" and Crouse-Hinds "Chico® A" cement.

† Turning radius with cover or plug removed.

** Per Nec 501(c)(6), seals in Class I, Division 1 and 2 must be limited to conductor fill of 25% of cross sectional area of a rigid metal conduit of the same trade size unless approved for higher percentage fill. See 40% fill seals on page I-9.