EDS / EFS Series Control Stations

Fully Assembled EDS Factory Sealed General Use Snap Switches

Cl. I, Div. 1 & 2, Groups B*, C, D
Cl. II, Div. 1, Groups E, F, G
Cl. II, Div. 2, Groups F, G
Cl. III
NEMA 3, 7B*CD, 9EFG

Explosionproof
Dust-Ignitionproof
Raintight
Wet Locations



EDSC2129



EDS2229

Dimensions
see page 526

Ordering Information - General Use Snap Switch – Front Operated

Hub Size	Style†	Amperes 120VAC§	Amperes 277VAC§	Single Gang Dead End Cat. #	Single Gang Through Feed Cat. #	Two Gang‡ Dead End Cat. #	Two Gang‡ Through Feed Cat. #	Factory Sealed Replacement Switch
¾	1-pole	20	20	**EDS2129**	**EDSC2129†**	**EDS2229**	**EDSC2229†**	SW5
¾	2-pole	20	20	**EDS218**	**EDSC218†**		**EDSC228†**	SW6
¾	3-way	20	20	**EDS2130**	**EDSC2130**	**EDS2230**	**EDSC2230**	SW7
¾	4-way	20	20	**EDS2140**	**EDSC2140**		**EDSC2240**	SW8
1	1-pole	20	20	**EDS3129**	**EDSC3129†**	**EDS3229**	**EDSC3229†**	SW5
1	2-pole	20	20	**EDS318**	**EDSC318†**	**EDS328**	**EDSC328†**	SW6
1	3-way	20	20	**EDS3130**	**EDSC3130**	**EDS3230**	**EDSC3230**	SW7
1	4-way	20	20	**EDS3140**	**EDSC3140**	**EDS3240**	**EDSC3240**	SW8

*Standard as Class I, Division 2, Group B. No seals required. For Class I, Division 1, Group B: All units on this page can be modified for Class I, Division 1, Group B usage. Add suffix GB to the Cat. No. Seals must be installed within 1½" of each conduit opening in Division 1.
† ON-OFF standard marking for 1-pole and 2-pole units.
‡ Combinations of switches can be furnished.
§ AC rated switches are tested for resistive, inductive and tungsten filament loads up to the full current rating and for motor loads up to 80% of the ampere rating.

Copyright© 2013 Eaton's Crouse-Hinds Business