


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:119.87V I:0.0948A P:7.8409W PF:0.6897 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:570.78x1 lm		
NAME: LED-SL-PNL-3SQ-8W-5CCT-WH	TYPE:	WEIGHT:
SPEC.: 3500K	DIM.:	SERIAL No.:
MFR.: Envisionled	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 72.80 lm/W			
MODEL		I _{max} (cd)	201.9	S/MH(C0/180)	1.26
NOMINAL POWER(W)	8	LOR(%)	100.0	S/MH(C90/270)	1.24
RATED VOLTAGE(V)	120	TOTAL FLUX(lm)	570.78	η UP,DN(C0-180)	0.0,50.8
NOMINAL FLUX(lm)	570.78	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,49.2
LAMPS INSIDE	1	η up (%)	0.0	CIBSE SHR NOM	1.25
TEST VOLTAGE(V)	120	η down (%)	100.0	CIBSE SHR MAX	1.35

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3 °C
 Operators:
 Test Date: 2022-06-17

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
 Humidity: 65.0%
 Test Distance: 3.090m [K=1.0000]
 Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:


γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	197.7	198.8	199.1	199.0	198.6	197.9	197.5	197.5	0- 10	19.09	19.09	3.34,3.34
20	187.4	189.0	189.3	189.1	188.1	186.6	186.0	186.5	10- 20	54.70	73.78	12.9,12.9
30	170.4	172.3	172.9	172.7	171.4	169.2	168.4	168.7	20- 30	82.93	156.7	27.5,27.5
40	147.6	149.5	150.5	150.2	148.9	146.1	145.5	145.7	30- 40	100.1	256.8	45,45
50	120.2	122.1	122.8	122.4	121.7	118.3	117.8	117.9	40- 50	103.9	360.7	63.2,63.2
60	88.73	90.58	91.48	90.97	90.29	86.87	86.44	86.39	50- 60	93.87	454.6	79.6,79.6
70	55.19	56.61	56.28	56.53	56.46	53.20	51.23	52.40	60- 70	71.21	525.8	92.1,92.1
80	20.80	20.33	18.34	21.28	21.52	16.57	14.17	17.47	70- 80	38.55	564.3	98.9,98.9
90	0.2305	0.2060	0.1980	0.2061	0.1438	0.1188	0.1094	0.1276	80- 90	6.454	570.8	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2022-06-17

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

LUMINANCE LIMITATION CURVES

Test:U:119.87V I:0.0948A P:7.8409W PF:0.6897 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:570.78x1 lm		
NAME: LED-SL-PNL-3SQ-8W-5CCT-WH	TYPE:	WEIGHT:
SPEC.: 3500K	DIM.:	SERIAL No.:
MFR.: Envisionled	SUR.:	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 2022-06-17

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity: 65.0%
Test Distance: 3.090m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:119.87V I:0.0948A P:7.8409W PF:0.6897 Freq:59.98Hz			UTHDi:0.00% ITHDi:0.00% KDisp:0			Lamp Flux:570.78x1 lm		
NAME: LED-SL-PNL-3SQ-8W-5CCT-WH			TYPE:			WEIGHT:		
SPEC.: 3500K			DIM.:			SERIAL No.:		
MFR.: Envisionled			SUR.:			Shielding Angle:		

pcc	80%			70%			50%			30%			10%			0
p _w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
p _{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio															



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2022-06-17

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:119.87V I:0.0948A P:7.8409W PF:0.6897 Freq:59.98Hz		
UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:570.78x1 lm		
NAME: LED-SL-PNL-3SQ-8W-5CCT-WH	TYPE:	WEIGHT:
SPEC.: 3500K	DIM.:	SERIAL No.:
MFR.: Envisionled	SUR.:	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)										
0.0																	
1.0	.301	.171	.054	.294	.168	.053	.281	.161	.051	.269	.155	.050	.258	.149	.048		
2.0	.287	.157	.048	.281	.155	.048	.269	.150	.047	.259	.145	.045	.249	.141	.044		
3.0	.267	.142	.043	.262	.140	.042	.251	.136	.041	.242	.133	.041	.233	.129	.040		
4.0	.247	.129	.038	.243	.127	.038	.233	.124	.037	.225	.121	.036	.217	.118	.036		
5.0	.229	.117	.034	.225	.115	.034	.217	.113	.033	.209	.110	.033	.202	.108	.032		
6.0	.213	.107	.031	.209	.106	.030	.202	.103	.030	.195	.101	.030	.189	.099	.029		
7.0	.198	.098	.028	.195	.097	.028	.188	.095	.027	.182	.093	.027	.177	.092	.027		
8.0	.185	.090	.025	.182	.090	.025	.176	.088	.025	.171	.087	.025	.166	.085	.025		
9.0	.174	.084	.023	.171	.083	.023	.166	.082	.023	.161	.081	.023	.156	.079	.023		
10.0	.163	.078	.022	.161	.078	.022	.156	.077	.022	.152	.075	.021	.148	.074	.021		

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.180	.156	.135	.154	.134	.116	.105	.092	.080	.061	.053	.047	.019	.017	.015	
2.0	.172	.132	.099	.147	.114	.085	.101	.079	.059	.058	.046	.035	.019	.015	.011	
3.0	.164	.114	.075	.141	.099	.065	.097	.068	.045	.056	.040	.027	.018	.013	.009	
4.0	.156	.101	.059	.134	.087	.051	.092	.061	.036	.053	.036	.021	.017	.012	.007	
5.0	.149	.091	.047	.128	.078	.041	.088	.055	.029	.051	.032	.017	.016	.010	.006	
6.0	.142	.082	.039	.122	.071	.034	.084	.050	.024	.049	.029	.014	.016	.010	.005	
7.0	.135	.075	.033	.116	.065	.029	.080	.046	.021	.047	.027	.012	.015	.009	.004	
8.0	.129	.069	.029	.111	.060	.025	.077	.042	.018	.045	.025	.011	.014	.008	.004	
9.0	.123	.065	.025	.106	.056	.022	.073	.039	.016	.043	.023	.009	.014	.008	.003	
10.0	.117	.060	.022	.101	.052	.020	.070	.037	.014	.041	.022	.008	.013	.007	.003	

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2022-06-17

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:119.87V I:0.0948A P:7.8409W PF:0.6897 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:570.78x1 lm											
NAME: LED-SL-PNL-3SQ-8W-5CCT-WH						TYPE:			WEIGHT:		
SPEC.: 3500K						DIM.:			SERIAL No.:		
MFR.: Envisionled						SUR.:			Shielding Angle:		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3	
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3	
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	
Room dimensions	Viewed crosswise					Viewed endwise					
x = 2H y = 2H	2H	16.6	18.2	16.9	18.4	18.6	16.8	18.3	17.0	18.5	18.7
	3H	18.2	19.6	18.5	19.8	20.0	18.3	19.7	18.6	19.9	20.2
	4H	18.7	20.1	19.1	20.3	20.6	18.8	20.2	19.1	20.4	20.7
	6H	19.1	20.4	19.4	20.6	20.9	19.1	20.4	19.4	20.6	20.9
	8H	19.2	20.4	19.5	20.7	21.0	19.2	20.4	19.5	20.7	20.9
	12H	19.2	20.4	19.6	20.7	21.0	19.1	20.3	19.5	20.6	20.9
4H	2H	17.3	18.6	17.6	18.9	19.1	17.4	18.7	17.7	19.0	19.2
	3H	19.0	20.1	19.3	20.4	20.7	19.1	20.2	19.4	20.5	20.8
	4H	19.7	20.8	20.1	21.1	21.4	19.7	20.8	20.1	21.1	21.4
	6H	20.2	21.1	20.6	21.5	21.8	20.1	21.1	20.5	21.4	21.8
	8H	20.3	21.2	20.7	21.5	21.9	20.2	21.1	20.6	21.4	21.8
	12H	20.4	21.2	20.8	21.6	22.0	20.2	21.0	20.6	21.4	21.8
8H	4H	19.9	20.8	20.4	21.2	21.6	20.0	20.9	20.4	21.2	21.6
	6H	20.6	21.3	21.0	21.7	22.1	20.5	21.2	20.9	21.6	22.0
	8H	20.7	21.4	21.2	21.8	22.3	20.6	21.2	21.1	21.7	22.1
	12H	20.9	21.4	21.3	21.9	22.3	20.6	21.1	21.1	21.6	22.1
12H	4H	19.9	20.7	20.4	21.1	21.5	20.0	20.8	20.4	21.2	21.6
	6H	20.6	21.2	21.0	21.6	22.1	20.5	21.1	21.0	21.6	22.0
	8H	20.8	21.3	21.3	21.8	22.3	20.6	21.2	21.1	21.6	22.1
Variations with the observer position at spacings(CIE Pub.117):											
S = 1.0H	+ 0.2 / - 0.2					+ 0.2 / - 0.2					
1.5H	+ 0.2 / - 0.3					+ 0.2 / - 0.3					
2.0H	+ 0.2 / - 0.3					+ 0.2 / - 0.3					

CIE Pub.117, 570.8 lm Total Lamp Luminous Flux Correct (8log(F/F0) = -1.9)
Area: 0.111111 m2

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2022-06-17

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:119.87V I:0.0948A P:7.8409W PF:0.6897 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:570.78x1 lm		
NAME: LED-SL-PNL-3SQ-8W-5CCT-WH	TYPE:	WEIGHT:
SPEC.: 3500K	DIM.:	SERIAL No.:
MFR.: Envisionled	SUR.:	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	58	46	39	57	46	39	56	45	39	32
0.80	68	56	49	67	56	49	65	55	48	41
1.00	76	65	58	75	65	58	73	66	57	50
1.25	83	73	66	82	72	66	79	71	65	57
1.50	88	79	72	87	78	71	84	76	70	63
2.00	95	87	81	94	86	80	90	83	78	70
2.50	99	92	86	97	90	85	93	88	83	75
3.00	103	96	90	100	94	89	96	91	87	79
4.00	107	101	96	104	99	95	100	96	92	84
5.00	109	104	100	107	102	99	102	99	96	87
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3°C
Operators:
Test Date: 2022-06-17

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity: 65.0%
Test Distance: 3.090m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:119.87V I:0.0948A P:7.8409W PF:0.6897 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:570.78x1 lm		
NAME: LED-SL-PNL-3SQ-8W-5CCT-WH	TYPE:	WEIGHT:
SPEC.: 3500K	DIM.:	SERIAL No.:
MFR.: Envisionled	SUR.:	Shielding Angle:




C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3℃
 Operators:
 Test Date:2022-06-17

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
 Humidity:65.0%
 Test Distance:3.090m [K=1.0000]
 Remarks:

AAI Figure

Test:U:119.87V I:0.0948A P:7.8409W PF:0.6897 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:570.78x1 lm		
NAME: LED-SL-PNL-3SQ-8W-5CCT-WH	TYPE:	WEIGHT:
SPEC.: 3500K	DIM.:	SERIAL No.:
MFR.: Envisionled	SUR.:	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3℃
 Operators:
 Test Date:2022-06-17

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
 Humidity:65.0%
 Test Distance:3.090m [K=1.0000]
 Remarks:

ISOLUX DIAGRAM

Test:U:119.87V I:0.0948A P:7.8409W PF:0.6897 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:570.78x1 lm		
NAME: LED-SL-PNL-3SQ-8W-5CCT-WH	TYPE:	WEIGHT:
SPEC.: 3500K	DIM.:	SERIAL No.:
MFR.: Envisionled	SUR.:	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2022-06-17

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:119.87V I:0.0948A P:7.8409W PF:0.6897 Freq:59.98Hz UTHDi:0.00% ITHDi:0.00% KDisp:0 Lamp Flux:570.78x1 lm		
NAME: LED-SL-PNL-3SQ-8W-5CCT-WH	TYPE:	WEIGHT:
SPEC.: 3500K	DIM.:	SERIAL No.:
MFR.: Envisionled	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	1549
L_0~180 (75) av	1322
L_0~180 (85) av	942
L_90~270 (65) av	1528
L_90~270 (75) av	1187
L_90~270 (85) av	84
L_45 (65) av	1530
L_45 (75) av	1282
L_45 (85) av	257

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3℃
Operators:
Test Date:2022-06-17

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3 °C
 Operators:
 Test Date: 2022-06-17

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
 Humidity: 65.0%
 Test Distance: 3.090m [K=1.0000]
 Remarks:

```

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-SPEX500_V1 SYSTEM V2.00.460
Humidity:65.0%
Test Distance:3.090m [K=1.0000]
Remarks:

```